

FIRE SAFETY DIRECTOR
(Refer to reference guide for all questions)
Underlined word in Questions 1-5 provide direction

1. The hose nozzle that is part of the standpipe systems must be tested _____.
- A. Annually – C of F holder for standpipe system can perform test
 - B. Quarterly – Master Plumber License with C of F for standpipe can perform test
 - C. Annually - Master Plumber License with C of F for standpipe can perform test
 - D. Quarterly - C of F holder for standpipe system can perform test

2. If your building has a water storage tank with temperature alarms, the water temperature alarms must be tested in cold weather at least _____.
- A. weekly
 - B. daily
 - C. quarterly
 - D. monthly

3. Remote annunciators in fire alarm systems must be inspected at least _____.
- A. weekly
 - B. monthly
 - C. quarterly
 - D. semi-annually

4. The sprinkler heads in a sprinkler system must be inspected by a Certificate of Fitness holder at least _____.
- A. monthly
 - B. weekly
 - C. annually
 - D. quarterly

5. The fire pump (electric pump) must be tested weekly a minimum of at least _____ minutes.
- A. 10
 - B. 15
 - C. 20
 - D. 30

6. Control valves in sprinkler systems require maintenance at least _____.

- A. semi-annually
- B. quarterly
- C. monthly
- D. annually

7. Hose connections in standpipe systems must be maintained at least _____.

- A. semi-annually- (standpipe C of F holder can perform maintenance)
- B. annually - (standpipe C of F holder can perform maintenance)
- C. semi-annually (Master Plumber License with C of F) can perform maintenance
- D. annually (Master Plumber License with C of F) can perform maintenance

8. Control valves equipped with tamper switches that are part of a standpipe system must be inspected by a Certificate of Fitness holder at least _____.

- A. semi-annually
- B. monthly
- C. quarterly
- D. weekly

9. Which of the following individuals is permitted to test the sprinkler system anti-freeze solution?

- A. A person who only has a Certificate of Fitness for Citywide Sprinkler Systems.
- B. A Refrigeration Operating Engineer (Q-99)
- C. A Licensed Master Plumber with a Cof F (S-12) for Citywide Sprinkler System.
- D. A Refrigeration Operating Engineer (Q-99) with a Cof F (S-12) for Sprinkler System

10 . The emergency voice/alarm communications equipment must be tested _____.

- A. semi-annually by an S-95 C of F holder
- B. annually by an S-95 C of F holder
- C. semi-annually by a W-26 C of F holder
- D. annually by a W-26 C of F holder

11. If your building has fire alarm devices that have apparent physical damage, the tag used shall be which color?

- A. Green
- B. Yellow
- C. Orange
- D. Red